

# The Chemical Company

### 1.6 PROJECT CONDITIONS

Do not use products under conditions of precipitation, or in inclement or freezing weather. Verify that A. substrates are clean, dry, and frost-free. Use appropriate measures for protection and supplementary heating to ensure proper curing conditions per manufacturer's recommendations if application during inclement weather occurs.

### 1.7 WARRANTY

- Provide manufacturer's 5 year standard material warranty A.
- Include coverage for replacement of sealant materials which fail to achieve water tight seal, exhibit loss of adhesion or cohesion, or do not cure, provided sealant has been installed per manufacturer's recommendations.
- Warranty Exclusions: Failure resulting from concrete shrinkage, structural cracks or defects, excessive movement, faulty construction, faulty design, faulty materials (other than joint sealants), improper installation, misuse of structure, settlement, or accident, fire, or other casualty or physical damage.

KRC NOTE Use in Florida and near the bay it not an exclusion

## PART 2 - PRODUCTS

#### 2.1 **MANUFACTURERS**

- Subject to compliance with requirements, provide products from the following manufacturer: A.
  - **BASF Building Systems** 1. 889 Valley Park Drive

Shakopee, MN 55379

Customer Service: 800-433-9517 Technical Service: 800-243-6739 Direct Phone: 952-496-6000

Internet: www.BASFbuildingsystems.com

- Substitutions: Comply with Section [01 60 00] [\_\_\_\_\_]. B.
- Specifications and Drawings are based on manufacturer's proprietary literature from BASF Building C. Systems. Other manufacturers shall comply with minimum levels of material, color selection, and detailing indicated in Specifications or on Drawings. Architect will be sole judge of appropriateness of substitutions.

### **MATERIALS** 2.2

- A premium-grade, high-performance, multi-component tintable, nonsag, silyl-terminated polyether A. elastomeric sealant. ASTM C 920 compliance:
  - Type and Grade: M (mulit component) and NS (nonsag). 1.
  - Class: 100/50 for vertical joints. 2.
  - Use Related to Exposure: NT (nontraffic). 3.
  - Uses Related to Joint Substrates: M, G, A, and, as applicable to joint substrates indicated, O. 4.
  - USDA compliant for use in meat and poultry areas. 5.
  - Acceptable Product: Sonolastic 150 Tint Base by BASF Building Systems.